FIRE ALARM AND EMERGENCY COMMUNICATION SYSTEM RECORD OF COMPLETION

To be completed by the system installation contractor at the time of system acceptance and approval. It shall be permitted to modify this form as needed to provide a more complete and/or clear record. Insert N/A in all unused lines.

Attach additional sheets, data, or calculations as necessary to provide a complete record.

1. PROPERTY INFORMATION

Name of property: NEWMAN & KORNBLITH	NEW BARN	
Address: 16 NASON HILL LANE SHERBORN	MA	
Description of property: RIDING STABLE		
Occupancy type: RIDING STABLE		
Name of property representative: MIKE NEWM	AN & POLLY KORNBLITH	
Address: 16 NASON HILL LANE SHERBORN	MA	
Phone: 617-566-7975 Fax:	E-mail:	mnewman@dragonnorth.com
Authority having jurisdiction over this property:	SHERBORN FIRE DEPT.	
Phone: 508-653-3270 Fax:	E-mail:	

2. INSTALLATION, SERVICE, AND TESTING CONTRACTOR INFORMATION

ddress: 1231 WASHINGTON	ST NEWTO	N, MA 02465	
icense or certification number:	C1523 / S	SCO 000620	
hone: 617-244-3355	Fax:	617-964-5804	E-mail: esther@shufro.com
rvice organization for this equip	oment: SI	UFRO SECURITY CO	INC
ddress: 1231 WASHINGTON	ST NEWTO	N,MA 02465	
cense or certification number:	C1523 / S	SCO 000620	
hone: 617-244-3355	Fax:	617-964-5804	E-mail: esther@shufro.com
contract for test and inspection	in accordance	ce with NFPA standard	s is in effect as of: 12.05.14
ntracted testing company:	HUFRO SE	CURITY CO INC	
ddress: 1231 WASHINGTON	ST NEWTO	N, MA 02465	•
		017 001 5001	E-mail: esther@shufro.com
one: 617-244-3355	Fax:	617-964-5804	E-mail: esther@shufro.com

3. DESCRIPTION OF SYSTEM OR SERVICE

Fire alarm system	m (nonvoice)		
☐ Fire alarm with	in-building fire em	ergency voice	alarm communication system (EVACS)
☐ Mass notificatio	n system (MNS)		and the second
Combination sys	stem, with the follo	owing compone	ents:
☐ Fire alarm	□ EVACS	☐ MNS	Two-way, in-building, emergency communication system
Other (specify):			

NFPA 72, Fig. 10.18.2.1.1 (p. 1 of 12)

<i>NFPA 72</i> edition: CMR 8^{TH} EDITION	Additional description of system(s): N/A
3.1 Control Unit Manufacturer: FIRELITE	Model number: ES200X
3.2 Mass Notification System	This system does not incorporate an MNS
3.2.1 System Type:	
□ In-building MNS—combination	
☐ In-building MNS—stand-alone ☐ Wide-a	rea MNS Distributed recipient MNS
Other (specify):	
3.2.2 System Features:	
Combination fire alarm/MNS	utonomous control unit 🗌 Wide-area MNS to regional national alerting interface
□ Local operating console (LOC) □ Direct n	recipient MNS (DRMNS)
□ Wide-area MNS to high-power speaker array (H	HPSA) interface In-building MNS to wide-area MNS interface
Other (specify):	
3.3 System Documentation	
An owner's manual, a copy of the manufacturer	r's instructions, a written sequence of operation, and a copy of
the numbered record drawings are stored on sit	te. Location: GIVEN TO BUILDING OWNER
3.4 System Software	This system does not have alterable site-specific software
Operating system (executive) software revision lev	/el:
Site-specific software revision date:	Revision completed by:
A copy of the site-specific software is stored on	site. Location:
3.5 Off-Premises Signal Transmission	This system does not have off-premises transmission.
Name of organization receiving alarm signals with	
Alarm:	Phone:
Supervisory:	Phone:
Trouble:	Phone:
Entity to which alarms are retransmitted:	Phone:
Method of retransmission:	
If Chapter 26, specify the means of transmission fr	rom the protected premises to the supervising station:
If Chapter 27, specify the type of auxiliary alarm s	system: Local energy Shunt Wired Wireless
	And a second

NFPA 72, Fig. 10.18.2.1.1 (p. 2 of 12)

3. DESCRIPTION OF SYSTEM OR SERVICE (continued)

4. CIRCUITS AND PATHWAYS

4.1 Signaling Line Pathways

4.1.1 Pathways Class Designations and	Survivability	
Pathways class: (See NFPA 72, Sections 12.3 and 12.4)	Survivability level:	Quantity:
4.1.2 Pathways Utilizing Two or More	Media	
Quantity:	Description:	
4.1.3 Device Power Pathways		
□ No separate power pathways from the	signaling line pathway	
Power pathways are separate but of the	e same pathway classification as	the signaling line pathway
Power pathways are separate and diffe	rent classification from the sign	aling line pathway
4.1.4 Isolation Modules		
Quantity:		
4.2 Alarm Initiating Device Pathways		
4.2.1 Pathways Class Designations and	Survivability	
Pathways class: (See NFPA 72, Sections 12.3 and 12.4)	Survivability level:	Quantity:
4.2.2 Pathways Utilizing Two or More	Media	
Quantity:	Description:	
4.2.3 Device Power Pathways		
\square No separate power pathways from the	initiating device pathway	
Power pathways are separate but of the	e same pathway classification as	the initiating device pathway
Power pathways are separate and diffe	rent classification from the initia	ating device pathway
4.3 Non-Voice Audible System Pathwa	ys	
4.3.1 Pathways Class Designations and	Survivability	
Pathways class: (See NFPA 72, Sections 12.3 and 12.4)	Survivability level:	Quantity:
4.3.2 Pathways Utilizing Two or More	Media	
Quantity:	Description:	
4.3.3 Device Power Pathways		
□ No separate power pathways from the	notification appliance pathway	
Power pathways are separate but of the	e same pathway classification as	the notification appliance pathway
Power pathways are separate and diffe	rent classification from the notif	fication appliance pathway

5. ALARM INITIATING DEVICES

5.1 Manual Initiating Devices			
5.1.1 Manual Fire Alarm Boxes	🖂 This	s system does not have	manual fire alarm boxes.
Type and number of devices: Addressable: 6	Conventional:	Coded:	Transmitter:
Other (specify):			
5.1.2 Other Alarm Boxes		This system does n	not have other alarm boxes.
Description:			
Type and number of devices: Addressable:	Conventional:	Coded:	Transmitter:
Other (specify):			
5.2 Automatic Initiating Devices			
5.2.1 Smoke Detectors		This system does n	not have smoke detectors.
Type and number of devices: Addressable: 2	Conventional:		
Other (specify):	<		
Type of coverage: \square Complete area \square Partial area	□ Nonrequired pa	rtial area	
Other (specify):			
Type of smoke detector sensing technology:	zation	etric 🗌 Multicriteria	Aspirating Beam
Other (specify):			
5.2.2 Duct Smoke Detectors	☑ This system doe	s not have alarm-causi	ing duct smoke detectors.
Type and number of devices: Addressable:	Conventional:		
Other (specify):			
Type of coverage:	F		
Type of smoke detector sensing technology: \Box Ioniz	zation Photoele	ctric Aspirating	🗌 Beam
5.2.3 Radiant Energy (Flame) Detectors	🛛 This	system does not have	radiant energy detectors.
Type and number of devices: Addressable:	Conventional:		
Other (specify):			
Type of coverage:			
5.2.4 Gas Detectors		This system do	bes not have gas detectors.
Type of detector(s):			
Number of devices: Addressable: Convent	ional:		
Type of coverage:			
5.2.5 Heat Detectors		This system do	bes not have heat detectors.
Type and number of devices: Addressable: 11	Conventional:		
Type of coverage: \square Complete area \square Partial area	a 🗌 Nonrequired	partial area ՝ 🗌 Linea	ar 🗌 Spot
Type of heat detector sensing technology: \Box Fixed to	emperature 🗌 Rat	e-of-rise 🔲 Rate co	ompensated

NFPA 72, Fig. 10.18.2.1.1 (p. 4 of 12)

5. ALARM INITIATING DEVICES (continued)

	5.2.6 Addressable Monitoring Modules Number of devices:		This system does not have	e monitoring modules.
	5.2.7 Waterflow Alarm Devices Type and number of devices: Addressable:	⊠ Thi Conventional:	is system does not have wa Coded:	terflow alarm devices. Transmitter:
	 5.2.8 Alarm Verification Number of devices subject to alarm verification: 5.2.9 Presignal Number of devices subject to presignal: Describe presignal functions: 		is system does not incorpor larm verification set for: ⊠ This system does not	seconds
	5.2.10 Positive Alarm Sequence (PAS) Describe PAS:		⊠ This system d	oes not incorporate PAS.
	5.2.11 Other Initiating Devices Describe:		This system does not have	e other initiating devices.
6.	SUPERVISORY SIGNAL-INITIATING DEVICE	S		
	6.1 Sprinkler System Supervisory Devices	🛛 This sy	stem does not have sprinkl	er supervisory devices.
	Type and number of devices: Addressable: Other (specify):	Conventional:	Coded:	Transmitter:
	6.2 Fire Pump Description and Supervisory Devices Type fire pump: Electric pump Engine		This system does	not have a fire pump.
	Type and number of devices: Addressable:	Conventional:	Coded:	Transmitter:
	Other (specify):			
	6.2.1 Fire Pump Functions Supervised □ Power □ Running □ Phase reversal □ Selecto Other (specify):	r switch not in auto	Engine or control pan	el trouble 🔲 Low fuel
	6.3 Duct Smoke Detectors (DSDs) Type and number of devices: Addressable: Other (specify):	This system Conventional:	n does not have DSDs caus	ing supervisory signals.

Type of coverage:

Describe:

Type of smoke detector sensing technology:
I Ionization
Photoelectric
Aspirating
Beam

6.4 Other Supervisory Devices

 \boxtimes This system does not have other supervisory devices. . 1

> 1 .

> > NFPA 72, Fig. 10.18.2.1.1 (p. 5 of 12)

7. MONITORED SYSTEMS

7.	.1 Engine-Driven Generator			⊠ This system	does not have a generator
7.	.1.1 Generator Functions Superv	ised			
	Engine or control panel trouble	Generator running	g 🗌 Selecto	r switch not in auto	Low fuel
] Other (specify):				
7.	2 Special Hazard Suppression Sy	stems	This s	ystem does not monito	or special hazard systems.
D	escription of special hazard system(s):			
7.	3 Other Monitoring Systems			This system does no	t monitor other systems.
De	escription of special hazard system(s):			
8. A	NNUNCIATORS			☑ This system doe	s not have annunciators.
8.	1 Location and Description of An	nunciators			
L	ocation 1: WEST ENTRANCE	×			
Lo	ocation 2:				
Lo	ocation 3:				
9. A	LARM NOTIFICATION APPLI	ANCES			
9.	1 In-Building Fire Emergency Vo	ice Alarm Communic	ation System	This system doe	s not have an EVACS.
Nı	umber of single voice alarm channe	ls:	Number of mu	ltiple voice alarm cha	
Nı	umber of speakers:		Number of spo	eaker circuits:	
Lo	ocation of amplification and sound-p	processing equipment:			
	ocation of paging microphone statio				
Lo	ocation 1:				
Lo	ocation 2:				
Lo	ocation 3:				
9.2	2 Nonvoice Notification Appliance	es D	This system do	es not have nonvoice	notification appliances.
Hc	orns: With visi		Bells:	With visil	
Ch	imes: With visi	ble:			

 Visible only:
 Other (describe):

 9.3 Notification Appliance Power Extender Panels

 \boxtimes This system does not have power extender panels.

Quantity:

Locations:

10. MASS NOTIFICATION CONTROLS, APPLIANCES, AND CIRCUITS In this system does not have an MNS.

	ting Consoles	
Location 1:		
Location 2:		
Location 3:		
10.2 High-Power Speak	er Arrays	
Number of HPSA speaker	r initiation zones:	
Location 1:		
Location 2:		
Location 3:		
10.3 Mass Notification I	Devices	
Combination fire alarm/M	INS visible appliances:	MNS-only visible appliances:
Textual signs:	Other (describe):	
Supervision class:		
10.3.1 Special Hazard N	otification	
This system does not h	ave special suppression predischar	ge notification.
	T override notification appliances on.	required to provide special suppression

1 2			
Number of telephone jacks installed:	1	Number of warden stations installed:	
Number of telephone handsets stored or	n site:		
Type of telephone system installed:] Electrically powe	red Sound powered	
11.2 Two-Way Radio Communicatio	ns Enhancement S	ystem	
This system does not have a two-way	y radio communicat	ions enhancement system.	
Percentage of area covered by two-way	radio service: Crit	tical areas: % General building areas:	%
Amplification component locations:			
Inbound signal strength:	dBm	Outbound signal strength:	dBm
Donor antenna isolation is:	dB ab	pove the signal booster gain	
Radio frequencies covered:			
Radio system monitor panel location:			

NFPA 72, Fig. 10.18.2.1.1 (p. 7 of 12)

11. TWO-WAY EMERGENCY COMMUNICATION SYSTEMS (continued)

11.3 Area of Refuge (Area of Rescue Assistance) Emergency Communications Systems

 Image: Constraint of the system does not have an area of refuge (area of rescue assistance) emergency communications system.

 Number of stations:
 Location of central control point:

 Days and hours when central control point is attended:
 Location of alternate control point:

 Days and hours when alternate control point is attended:
 Days and hours when alternate control point is attended:

11.4 Elevator Emergency Communications Systems

This system does not have an elevator emergency communications system.

Number of elevators with stations:

Location of central control point:

Days and hours when central control point is attended:

Location of alternate control point:

Days and hours when alternate control point is attended:

11.5 Other Two-Way Communication Systems

Describe:

12. CONTROL FUNCTIONS

This system activates the following control fuctions:

Hold-open door rele	asing devices	Smoke management	HVAC shutdown	\Box F/S dampers	
Door unlocking	Elevator recall	☐ Fuel source shutdo	wn 🗌 Extinguishin	ng agent release	
Elevator shunt trip	☐ Mass notifica	ation system override of fin	e alarm notification app	liances	

Other (specify):

12.1 Addressable Control Modules	This system does not have control module	
Number of devices:		
Other (specify):		

13. SYSTEM POWER

13.1	Contro	I Unit
TOOT	Contro	

13.1.1 Primary Power Input voltage of control panel:

Overcurrent protection: Type:	Amps:	
Location (of primary supply panel board):		
Disconnecting means location:		
13.1.2 Engine-Driven Generator	This system does not have a ge	enerator.
Location of generator:	manut . Ares -	
Location of fuel storage:	Type of fuel:	

Control panel amps:

NFPA 72, Fig. 10.18.2.1.1 (p. 8 of 12)

13. SYSTEM POWER (continued)

3.1.3 Uninterruptible Power System			
Equipment powered by a UPS system:			
Location of UPS system:			
Calculated capacity of UPS batteries to drive the system	a components connected to it:		
In standby mode (hours):	In alarm mode (minutes):		
13.1.4 Batteries			
Location: ALARM CONTROL Type: RECH PANEL EABLE GEL C	Timp/nour runng.		
Calculated capacity of batteries to drive the system:			
In standby mode (hours): 24 HRS	In alarm mode (minutes): 5 MINUTES=1/20 HOUR		
Batteries are marked with date of manufacture	□ Battery calculations are attached		
13.2 In-Building Fire Emergency Voice Alarm Com	munication System or Mass Notification System		
This system does not have an EVACS or MNS syste			
13.2.1 Primary Power			
Input voltage of EVACS or MNS panel:	EVACS or MNS panel amps:		
Overcurrent protection: Type:			
Location (of primary supply panel board):			
Disconnecting means location:			
13.2.2 Engine-Driven Generator	This system does not have a generator.		
Location of generator:			
Location of fuel storage:	Type of fuel:		
13.2.3 Uninterruptible Power System	\boxtimes This system does not have a UPS.		
Equipment powered by a UPS system:			
Location of UPS system:			
Calculated capacity of UPS batteries to drive the system	components connected to it:		
In standby mode (hours):	In alarm mode (minutes):		
13.2.4 Batteries			
Location: Type:	Nominal voltage: Amp/hour rating:		
Calculated capacity of batteries to drive the system:			
In standby mode (hours):	In alarm mode (minutes):		
□ Batteries are marked with date of manufacture	Battery calculations are attached		

NFPA 72, Fig. 10.18.2.1.1 (p. 9 of 12)

13. SYSTEM POWER (continued)

13.3 Notification Appliance Po	ower Extender Panels	⊠ This system d	oes not have power extender panels.
13.3.1 Primary Power			
Input voltage of power extender	panel(s):	Power extender pa	anel amps:
Overcurrent protection: Type	2:	Amps:	
Location (of primary supply par	nel board):		
Disconnecting means location:			
13.3.2 Engine-Driven Generat	tor	🖂 TI	his system does not have a generator.
Location of generator:			
Location of fuel storage:		Type of fuel:	
13.3.3 Uninterruptible Power	System	D	This system does not have a UPS.
Equipment powered by a UPS s	ystem:		
Location of UPS system:			
Calculated capacity of UPS batt	eries to drive the system	components connected to it:	
In standby mode (hours):		In alarm mode (minutes):	
13.3.4 Batteries			
Location:	Туре:	Nominal voltage:	Amp/hour rating:
Calculated capacity of batteries	to drive the system:		
In standby mode (hours):		In alarm mode (minutes):	
Batteries are marked with date	te of manufacture	Battery calculations are attach	ned
4. RECORD OF SYSTEM IN			
Fill out after all installation is c branching, but before confucting	complete and wiring has l g operational acceptance	tests.	
	☐ Modification to an ex		
		lowing requirements: (Note any	or all that apply.)
■ NFPA 72, Edition: CMR 8 EDITIC			
NFPA 70, National Electrica	al Code, Article 760, Edit	ion:	
Manufacturer's published in	structions		
Other (specify):			
System deviations from referen	ced NFPA standards:		
XC	A		
Signed:	Printed	I name: RICHARD SHUFRO	Date: 02.05.19
Organization: SHUPROSE	CURITY CO Title:	INSTALLER	Phone: 617-244-3355

NFPA 72, Fig. 10.18.2.1.1 (p. 10 of 12)

15. RECORD OF SYSTEM OPERATIONAL ACCEPTANCE TEST

New system

All operational features and functions of this system were tested by, or in the presence of, the signer shown below, on the date shown below, and were found to be operating properly in accordance with the requirements for the following:

☐ Modifications to an existing system

All newly modified operational features and functions of the system were tested by, or in the presence of, the signer shown below, on the date shown below, and were found to be operating properly in accordance with the requirements of the following:

□ *NFPA 72*, Edition: CMR 8TH EDITION

□ NFPA 70, National Electrical Code, Article 760, Edition:

☐ Manufacturer's published instructions				
Other (specify):				
Individual device testing documentation [Ins	pection and Testi	ng Form (Figure 14.6.2.4) is at	ttached]	
Signed:	Printed name:	RICHARD SHUFRO	Date:	02.05.19
Organization: SHUFRO SECURITY CO	Title: INSTA	LLER	Phone:	617-244-3355

16. CERTIFICATIONS AND APPROVALS

16.1 System Installation Contractor:

This system, as specified herein, has been installed and tested according to all NFPA standards cited herein.

Signed:	Printed name: RICHARD SHUFRO	Date: 02.05.19
Organization: SHUFRO SECURITY CO	Title: INSTALLER	Phone: 617-244-3355

16.2 System Service Contractor:)

The undersigned has a service contract for this system in effect as of the date shown below.

Signed:	Printed name: RICHARD SHUFRO	Date: 02.05.19
Organization: 8HUFRO SECURITY CO	Title: INSTALLER	Phone: 617-244-3355

16.3 Supervising Station:

1

This system, as specified herein, will be monitored according to all NFPA standards cited herein.

Signed:	Printed name: RICHARD SHUFRO	Date: 02.05.19
Organization: SHUFRO SECURITY CO	Title: INSTALLER	Phone: 617-244-3355

16. CERTIFICATIONS AND APPROVALS (continued)

16.4 Property or Owner Representative:

This system, as specified herein, will be monitored according to all NFPA standards cited herein.

Signed:	Printed name:	Date:
Organization:	Title:	Phone:

16.5 Authority Having Jurisdiction:

I have witnessed a satisfactory acceptance test of this system and find it to be installed and operating properly in accordance with its approved plans and specifications, with its approved sequence of operations, and with all NFPA standards cited herein.

Signed:	Printed name:	Date:
Organization:	Title:	Phone: