

SHUFRO SECURITY CO. INC.

1231 Washington Street West Newton, MA. (617) 244-3355

Mike Newman & Polly Kornblith
16 Nason Hill Lane
Sherborn, Ma 01770

November 13, 2020

Good afternoon Mike & Polly,

This letter is notification that the fire alarm system in the barn on your property has been tested. All system devices and NAC circuits have been tested and function within manufacture's specifications. The power supply and backup power source were tested and are within normal limits. The devices in the caretaker's apartment were also tested and function according to manufacture's specifications. Communications to the central station was confirmed and the system was returned to normal. Richard Distefano and Lenny Constantino were the technicians on site performing the annual test.

Let me know if you have any questions.

Sincerely,



Esther Berbine
Shufro Security Co Inc
Lisc# 1523C
SSCO 000620